

**СЕКЦИЯ 1.  
ЭНЕРГОСБЕРЕЖЕНИЕ И ЭНЕРГОЭФФЕКТИВНОСТЬ**

**DESIGN OF A POWER UNIT OF AN AUTONOMOUS NUCLEAR POWER  
PLANT WITH A VVER-300 REACTOR**

M.O. Alsayed  
National Research Tomsk Polytechnic University  
Power Engineering School, REC named after I.N. Butakova, group 506И

**Introduction**

The design of the two-loop Reactor Plant (RP) with VVER-300 is based on engineering solutions for the equipment of previous designs of RP with VVER.

The VVER-300 is a proposed Russian pressurized water reactor of 325-MWe generating capacity designed for remote locations. The exterior containment structure is 16 meters high and the working section, built with transportable modules, weighs 1300 tonnes. The external steam plant can have a 917 MW thermal-steam only capacity, or 325 MW steam-turbine-electrical capacity, or a mixture of capacities relating to the four primary steam loops.[1]

In particular, it has been proposed in a more powerful sister ship to the *Akademik Lomonosov* (2010) for possible use on the Russian floating nuclear power station (two reactors on a 49,000-tonne barge). The reactor could be used on a 200–500 MW barge that is expected to be completed by 2030.[1]

The reactor has been proposed for use in water desalination, district heating and/or electrical generation.[1]

The present report aimed to design VVER-300 with horizontal steam generator.

**Description of the research object**

The design of my research object consists of designing of three variants of steam generator. The first is horizontal steam generator, The second is vertical steam generator with economizer zone and the third, is vertical steam generator without economizer zone.

The research work containing also designing thermal scheme of NPP with High- and Low-pressure turbine with intermediate separator and Superheater and designing of Regenerative feedwater heaters of closed type.



Feed water temperature. $t_{fw}$ , °C	220
Number of SG tubes	7341
Super-heater	One stage
Final pressure $P_c$ , kPa	5
Deaerator pressure $P_d$ , Mpa	0.64
No. of Low RFWH	4
No. of High RFWH	2
$N_e$ , MW	279.5
$\eta_{npp}^{Gross}$ , %	32.05
$\eta_{npp}^{net}$ , %	30.4
Specific flow rate of nuclear fuel (natural uranium) at nuclear power plants. $b_{nf}$ , g/(MW · h)	$29.3 \cdot 10^{-3}$
specific flow rate of degraded fuel for the electrical supply at nuclear power plants (block). $b_{Ndf}$ , MW	$176.35 \cdot 10^{-3}$

### Conclusion

We can be concluded; all calculations are met and acceptable according to conditions. The efficiency of NPP is 32.05 % and it is acceptable of range. The finally calculations of steam generators, the horizontal variant is best choice because Steam generators of horizontal type are used on NPPs with VVER reactors from the moment of initiation of development of nuclear power generation.

### LITERATURE:

1. Status report 66 - VVER-300  
<https://aris.iaesa.org/sites/..%5CPDF%5CVBER-300.pdf>.
2. Trunov, NB (OKB Hidropress, Podol'sk (Russian Federtion)) ; Lukasevich, BI (OKB Hidropress, Podol'sk (Russian Federation)) ; Veselov, DO (OKB Hidropress, Podol'sk (Russian Federation)) ; Dragunov, Yu.G. (OAO Atomehnergoprom, Moscow (Russian Federation)).

Scientific adviser: A.V. Vorobiev, candidate of technical sciences, associate professor of the Scientific and Educational Center I.N. Butakov of the Engineering School of Power Engineering of the Tomsk Polytechnic University.